



STATE OF DELAWARE
DEPARTMENT OF TRANSPORTATION
PO BOX 778
DOVER, DELAWARE 19903

JACK MARKELL
GOVERNOR

SHAIEN BHATT
SECRETARY

VIA OVERNIGHT DELIVERY

(302) 760-2030
FAX (302) 739-2254

July 14, 2011

Contract No. T201080105.01
CENTRAL DISTRICT ROOF REPLACEMENT
Kent County

Ladies and Gentlemen:

Enclosed is Addendum No. 1 for the referenced contract consisting of the following:

Clarifications from the Site visit.

1. The roof product will be the self adhered TPO. A TPO product with an applied Bonding Adhesive (even a "low VOC") will not be accepted.
2. The roof drains do not need to be removed and replaced completely. The retrofit roof drains are acceptable as shown on the plans.
3. The weight of the HVAC units on the shop roof are approximately 3,000 pounds. The HVAC unit over the Admin portion is approximately 7,000 pounds.

Please note the revisions listed above and submit your bid based upon this information.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott S. Gottfried".

Scott S. Gottfried
Competitively Bid Contracts Coordinator
:ssg
Enclosures